

SPECIFICATIONS

REACTOR SAND

The following sand is to be delivered only on an "as needed" basis upon call from the Sewer Plant Operator for delivery to:

Erie County Sewer District #3
3690 Lakeshore Rd
Buffalo NY 14219

Price quoted must include delivery and must remain firm for the period of January through December 31, 2008.

Please quote PRICE PER TON on an estimated annual usage of 200 Tons.

Reactor Sand Pelletized as follows:

A hard silica sand to be fluidized at 1500 F Degrees fluid bed. Moisture content not to exceed 1% at shipping point. Sand to be well washed and free of chlorides. Sand must not fuse or tend to fuse at 1800 F Degrees. U.S. Mesh – per cent retained - 8 + 20 - + 0 to 20 – 30 – 20 + 30 - + 1 to 30 – 30 + 40 - + 10 to 10 - 20 - 40 + 50 - + 10 to 10 - 20

UNIT PRICE	TOTAL PRICE
<u>\$ 149.00</u>	<u>\$29,800.00</u>

*22.5 TON TRUCKLOAD

15 - 3000 LB. SUPERSACKS OF REACTOR SAND PER SPEC ON PALLETS

Vendors may contact Randy Schweitzer or Kevin Kaminski at 716-823-8188 with any questions regarding this item or Delivery arrangements.

NAME OF BIDDER RICCI BROS. SAND CO., INC.